CIVIL XPERTS
ISO 9001:2008
CONSULTANTS & TESTING CENTER

174, Sri Ranga Complex
Amrutha Nagar Main Road
New Bank Colony, Konanakunte
Bangalore - 560 062.
Mobile : +91 97429 59595
Tele/Fax : 080-2632 2565
E-mail : civilexpertsltd@gmail.com
URL : www.civilexperts.in

NABL ACCREDITED AS PER ISO/IEC 17025:2005

Job No.: CECTC-RV-W N-16-2015-16

Date: 16.02.2015

TEST REPORT ON CONCRETE CUBES

Client : **Executive Engineer,** Rajarajeshwari Nagara Division, BBMP, Bangalore.
Agency : **Sri.Raghavendra,** contractor, Bangalore.
Name of the work : Providing RCC drain and Improvements to footpath at 1st A cross Sharadamba Nagara in Ward no.16
Reference : EE/RRND/W.O No/79/2014-15 Dated: 07.08.2014
Sample ID : Cement Concrete
Size of cubes : 150mmx150mmx150mm
Cross Sectional Area : 22500 mm^2
Technical Reference : IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete : M_{20}
Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	19.01.2015	16.02.2015	8.144	530.2	23.56
2	19.01.2015	16.02.2015	8.152	477.6	21.23
3	19.01.2015	16.02.2015	8.166	465.2	20.68

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 15 days from the date of testing.

For Civil Expert

Authorised Signature